


Bay Area WTP

Monthly Operations Report



August, 2019

Water Systems Serial Number: 0465



Ryan Goebel

Water Plant Superintendent

Title

F1

Classification



Mike Wagar

Operations Supervisor

Title

F2

Classification

Bay Area Water Treatment Plant

Monthly Operations Report

Supply Name: Bay Area Water System
WSSN: 0465

Ryan Goebel
Operator-in-charge

August, 2019
Month, Year

F1
Certification of Operator-in-charge

F1
Water Plant Classification

Bay
County

Treatment Rate and Membrane Data

Treatment Rate, Approved Rated Plant Capacity	<u>17.4</u>	Millions of Gallons per Day
Treatment Rate, Maximum	<u>11.7</u>	Millions of Gallons per Day
Maximum Approved Transmembrane Pressure	<u>22</u>	PSI
Maximum Operating Transmembrane Pressure	<u>22</u>	PSI

Chemical Data

Sodium Hypochlorite on hand:	<u>5,165</u>	Gallons	Estimated Supply:	<u>41.6</u>	days
Caustic Soda on hand:	<u>2,798</u>	Gallons	Estimated Supply:	<u>218.6</u>	days
Corrosion Inhibitor on hand:	<u>764</u>	Gallons	Estimated Supply:	<u>24.2</u>	days
Hydrofluosilicic Acid on hand:	<u>1,386</u>	Gallons	Estimated Supply:	<u>44.4</u>	days
Aluminum Chlorohydrate on hand:	<u>498</u>	Gallons	Estimated Supply:	<u>27.5</u>	days
Sulfuric Acid on hand:	<u>858</u>	Gallons	Estimated Supply:	<u>249.7</u>	days
Sodium Bisulfite on hand:	<u>902</u>	Gallons	Estimated Supply:	<u>141.8</u>	days
Citric Acid on hand:	<u>2,588</u>	Gallons	Estimated Supply:	<u>277.3</u>	days
Cost of All Chemicals per Million Gallons:	<u>71.84</u>	Dollars			
Estimated Electrical Cost per Million Gallons:	<u>85.11</u>	Dollars			
Estimated Natural Gas Cost per Million Gallons:	<u>0.058</u>	Dollars			

Remarks

Number of periods of filter confluence turbidity samples > 0.3 NTU 0
Percent of membrane period confluence samples > 0.3 NTU: 0.00%

Did any individual membrane skid exceed:

1.0 NTU in two consecutive measurements taken 15 minutes apart?
If yes, attach specific filter(s) information and indicate required follow-up status. No

0.5 NTU in two consecutive measurements taken 15 minutes apart after 4 hours of operation?
If yes, attach specific filter(s) information and indicate required follow-up status. No

1.0 NTU in two consecutive measurements taken 15 minutes apart for 3 consecutive months?
If yes, attach specific filter(s) information and indicate required follow-up status. No

2.0 NTU in two consecutive measurements taken 15 minutes apart for 2 consecutive months?
If yes, attach specific filter(s) information and indicate required follow-up status. No

Was continuous (every 15 minutes) filter monitoring equipment off-line during the month?
If yes, indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet. No

Did POE disinfectant residual fall below 0.2 ppm during the month?
If yes, indicate date(s) and duration on a separate sheet. No

Was minimum C*T credit achieved for the entire month?
If no, indicate on a separate sheet the date(s) not achieved. Yes

Was continuous POE chlorine residual monitoring equipment off-line during the month?
If yes, date(s) and duration will be indicated on the rule page. No

Notes

Filter #4 offline at 8:30pm on 8/23/19 for broken drain line(passed AHT that day), Back online at 11:10am on 8/26/19 after repair.



Bay Area WTP Monthly Operating Report

Date	Flows									
	Raw Water (MG)			Clarified (MG)	Wasted (MG)	Sludge (MG)	Treated (MG)	Finished Water Pumped (MG)		
	North	South	Total	Total	Total	Total	Total	N. Euclid	Lauria Road	Total
FIT-1000-1	FIT-1000-2	Calculated	FIT-5520-1	FIT-5520-2	FIT-5180	FIT-4000-1	FIT-4040-1	FIT-4040-2	Calculated	
8/1/2019	4.84	8.41	13.25	0.38	0.00	0.08	11.12	5.82	5.20	11.02
8/2/2019	5.44	5.77	11.21	0.39	0.00	0.08	11.17	5.79	5.16	10.95
8/3/2019	4.93	4.50	9.43	0.34	0.00	0.10	10.41	5.46	4.84	10.29
8/4/2019	4.90	6.02	10.92	0.26	0.00	0.22	10.71	5.57	4.96	10.53
8/5/2019	4.52	8.17	12.69	0.23	0.00	0.25	11.73	6.07	5.48	11.56
8/6/2019	3.88	6.07	9.95	0.25	0.00	0.18	9.69	4.96	4.53	9.49
8/7/2019	4.69	5.04	9.73	0.32	0.00	0.13	10.79	5.58	5.04	10.62
8/8/2019	5.27	5.83	11.10	0.35	0.00	0.08	9.44	4.94	4.36	9.29
8/9/2019	4.52	5.13	9.65	0.33	0.00	0.08	9.90	5.09	4.67	9.77
8/10/2019	4.60	5.25	9.85	0.37	0.00	0.08	10.08	5.04	4.75	9.79
8/11/2019	4.37	5.58	9.95	0.33	0.00	0.08	10.55	5.28	4.97	10.25
8/12/2019	5.00	5.95	10.96	0.38	0.00	0.09	11.13	5.60	5.30	10.90
8/13/2019	5.43	6.15	11.58	0.38	0.00	0.09	11.53	5.90	5.36	11.26
8/14/2019	5.38	6.39	11.78	0.36	0.00	0.08	10.58	5.63	5.03	10.66
8/15/2019	4.49	5.74	10.23	0.32	0.00	0.08	9.54	4.81	4.35	9.16
8/16/2019	3.18	5.94	9.11	0.29	0.00	0.10	9.09	4.78	4.24	9.02
8/17/2019	3.37	5.07	8.44	0.15	0.00	0.22	9.17	4.74	4.24	8.97
8/18/2019	4.24	4.95	9.19	0.24	0.00	0.20	9.64	4.98	4.49	9.47
8/19/2019	5.41	5.65	11.06	0.34	0.00	0.11	10.80	5.54	5.08	10.62
8/20/2019	5.51	5.40	10.90	0.27	0.00	0.14	10.42	5.37	4.89	10.26
8/21/2019	4.98	4.90	9.89	0.29	0.00	0.10	9.17	4.80	4.24	9.04
8/22/2019	3.79	4.26	8.06	0.34	0.00	0.08	10.00	5.19	4.59	9.78
8/23/2019	5.30	4.86	10.16	0.31	0.00	0.08	9.52	5.00	4.41	9.41
8/24/2019	6.86	3.88	10.74	0.32	0.00	0.08	10.18	5.30	4.73	10.04
8/25/2019	6.72	3.79	10.50	0.27	0.00	0.17	9.96	5.15	4.58	9.72
8/26/2019	5.90	3.96	9.86	0.16	0.00	0.24	9.53	5.02	4.47	9.48
8/27/2019	4.58	4.34	8.92	0.20	0.00	0.21	9.08	4.70	4.20	8.90
8/28/2019	4.86	5.34	10.20	0.20	0.00	0.21	9.71	5.01	4.46	9.47
8/29/2019	4.34	4.47	8.81	0.23	0.00	0.15	9.16	4.79	4.26	9.05
8/30/2019	4.16	4.09	8.25	0.27	0.00	0.13	9.03	4.70	4.17	8.87
8/31/2019	4.80	4.60	9.40	0.28	0.00	0.10	8.42	4.38	3.88	8.26
Total	4.76	4.23	315.75	9.15	0.00	4.05	8.22	4.28	3.81	305.90
Avg	4.85	5.34	10.19	0.30	0.00	0.13	10.04	5.19	4.68	9.87
Min	3.18	3.79	8.06	0.15	0.00	0.08	8.42	4.38	3.88	8.26
Max	6.86	8.41	13.25	0.39	0.00	0.25	11.73	6.07	5.48	11.56



Raw Water Analysis								
Date	Temp	pH	Turbidity		F ⁻	Free Cl	Bacti	
	Average	Average	Average	Maximum	Grab	Average	Positive/Negative	
	°C		NTU		mg/L	mg/L	Total Coliform	E. coli
	TIT-1000	AIT-1000-2	AIT-1000-1		Lab	AIT-1035-2	Lab	
8/1/2019	19.65	8.04	0.42	0.73	0.09	0.30	Negative	Negative
8/2/2019	19.99	8.14	0.49	0.72	0.09	0.27	Negative	Negative
8/3/2019	20.32	8.22	0.58	1.02	0.09	0.24	Negative	Negative
8/4/2019	20.55	8.21	0.53	2.05	0.09	0.29	Negative	Negative
8/5/2019	20.74	8.22	0.53	0.89	0.09	0.30	Negative	Negative
8/6/2019	20.96	8.19	0.72	2.62	0.09	0.25	Negative	Negative
8/7/2019	20.73	8.02	0.46	1.16	0.08	0.34	Negative	Negative
8/8/2019	20.27	7.95	0.44	2.45	0.09	0.42	Negative	Negative
8/9/2019	19.80	7.86	0.61	0.99	0.08	0.37	Negative	Negative
8/10/2019	18.97	7.83	0.67	2.37	0.06	0.48	Negative	Negative
8/11/2019	18.56	7.85	0.87	2.02	0.08	0.53	Negative	Negative
8/12/2019	18.76	7.94	0.60	1.66	0.08	0.43	Negative	Negative
8/13/2019	19.03	8.00	0.47	1.83	0.08	0.43	Negative	Negative
8/14/2019	19.40	8.02	0.41	0.74	0.08	0.40	Negative	Negative
8/15/2019	19.85	7.99	0.66	2.31	0.09	0.35	Negative	Negative
8/16/2019	20.13	8.09	1.51	3.04	0.09	0.14	Positive	Negative
8/17/2019	20.38	8.02	0.83	1.54	0.09	0.34	Negative	Negative
8/18/2019	20.55	8.04	0.77	1.33	0.08	0.28	Negative	Negative
8/19/2019	20.68	7.96	1.12	4.26	0.09	0.14	Negative	Negative
8/20/2019	20.73	7.87	0.83	1.77	0.09	0.20	Negative	Negative
8/21/2019	20.72	7.79	0.68	2.59	0.09	0.24	Negative	Negative
8/22/2019	20.52	7.80	0.64	1.40	0.09	0.21	Negative	Negative
8/23/2019	20.26	7.78	0.78	5.41	0.09	0.54	Negative	Negative
8/24/2019	20.40	7.92	0.90	1.78	0.09	0.22	Negative	Negative
8/25/2019	20.66	8.07	1.53	2.48	0.09	0.09	Positive	Negative
8/26/2019	20.80	8.11	1.66	2.91	0.09	0.07	Positive	Negative
8/27/2019	20.87	8.13	1.73	4.42	0.09	0.05	Positive	Negative
8/28/2019	20.84	8.08	1.76	3.63	0.10	0.05	Positive	Negative
8/29/2019	20.76	8.00	1.43	3.86	0.09	0.10	Negative	Negative
8/30/2019	20.12	7.77	0.76	3.79	0.08	0.62	Negative	Negative
8/31/2019	18.37	7.75	0.77	2.13	0.08	0.99	Negative	Negative
Avg	20.1	7.99	0.84	2.25	0.09	0.31	NA	NA
Min	18.4	7.75	0.41	0.72	0.06	0.05	NA	NA
Max	21.0	8.22	1.76	5.41	0.10	0.99	NA	NA



Finished Water Analysis																		
Date	Temp	pH	Phosphate	Fluoride		Free Cl ₂	Alkalinity (as CaCO ₃)		Chloride	Sulfate	Calcium (as CaCO ₃)	Dissolved Oxygen	Conductivity	Langelier Saturation Index	Chloride: Sulfate Mass Ratio	Larson-Skold Index	Bacti	
	Average	Average	Average	Tap	Dist	Average	Carbonate	Bicarbonate	Grab	Grab	Grab	Grab	Grab				Positive/Negative	
	°C		mg/L	mg/L		mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	uS/cm				Total Coliform	E. coli
	AIT-4040-1	AIT-4050-2	AIT-4040-5	Lab		AIT-4050-1	Lab		Lab	Lab	Lab	Lab	Lab	Calculated		Lab		
8/1/2019	19.0	7.47	3.43	0.80		1.22	0	75	11	14	76	8.6	217	-0.75	0.76	0.49	Negative	Negative
8/2/2019	19.5	7.50	3.43	0.81		1.21	0	78	11	12	74	8.5	226	-0.71	0.91	0.44	Negative	Negative
8/3/2019	20.1	7.53	3.44	0.82		1.20	0	78	11	13	72	7.8	233	-0.68	0.85	0.46	Negative	Negative
8/4/2019	20.6	7.55	3.43	0.81		1.21	0	78	11	11	70	8.2	235	-0.66	1.00	0.43	Negative	Negative
8/5/2019	20.9	7.55	3.42	0.79	0.82	1.23	0	77	11	12	74	7.9	231	-0.64	0.92	0.45	Negative	Negative
8/6/2019	21.2	7.56	3.40	0.78		1.20	0	88	11	13	74	8.4	235	-0.56	0.83	0.40	Negative	Negative
8/7/2019	20.9	7.54	3.40	0.77		1.23	0	80	10	8	64	8.1	225	-0.69	1.25	0.34	Negative	Negative
8/8/2019	20.1	7.49	3.40	0.78		1.25	0	79	11	11	72	7.5	217	-0.71	0.99	0.42	Negative	Negative
8/9/2019	19.4	7.48	3.39	0.76		1.21	0	79	11	11	80	8.6	715	-0.79	0.95	0.41	Negative	Negative
8/10/2019	18.1	7.50	3.38	0.74		1.23	0	78	11	11	67	8.8	219	-0.78	1.00	0.43	Negative	Negative
8/11/2019	16.9	7.49	3.37	0.80		1.23	0	78	10	13	70	9.0	219	-0.80	0.77	0.44	Negative	Negative
8/12/2019	16.8	7.49	3.36	0.76	0.73	1.22	0	78	10	11	64	8.5	219	-0.84	0.91	0.40	Negative	Negative
8/13/2019	17.5	7.51	3.37	0.78		1.24	0	74	10	11	82	9.2	217	-0.72	0.91	0.42	Negative	Negative
8/14/2019	18.2	7.53	3.38	0.78		1.24	0	74	10	11	80	9.0	214	-0.70	0.91	0.42	Negative	Negative
8/15/2019	18.9	7.45	3.37	0.77		1.21	0	74	11	10	80	9.1	215	-0.75	1.05	0.42	Negative	Negative
8/16/2019	19.6	7.43	3.37	0.78		1.19	0	75	11	11	84	8.3	219	-0.73	1.00	0.44	Negative	Negative
8/17/2019	20.2	7.46	3.37	0.80		1.19	0	78	12	12	86	8.1	233	-0.67	0.96	0.45	Negative	Negative
8/18/2019	20.5	7.44	3.37	0.81		1.21	0	76	12	11	80	8.1	226	-0.73	1.06	0.45	Negative	Negative
8/19/2019	20.7	7.43	3.38	0.81		1.22	0	76	11	11	82	7.3	227	-0.72	1.03	0.44	Negative	Negative
8/20/2019	20.8	7.41	3.39	0.83		1.21	0	80	10	12	74	8.1	231	-0.76	0.83	0.41	Negative	Negative
8/21/2019	20.7	7.38	3.39	0.76	0.79	1.22	0	80	11	12	80	7.8	226	-0.75	0.92	0.43	Negative	Negative
8/22/2019	20.4	7.37	3.38	0.74		1.23	0	74	11	13	68	7.8	225	-0.88	0.88	0.49	Negative	Negative
8/23/2019	20.0	7.35	3.39	0.77		1.23	0	75	10	12	66	8.0	222	-0.91	0.81	0.43	Negative	Negative
8/24/2019	19.9	7.36	3.39	0.77		1.21	0	74	11	13	74	7.9	226	-0.86	0.85	0.48	Negative	Negative
8/25/2019	20.4	7.40	3.39	0.79		1.18	0	78	11	13	72	7.9	239	-0.80	0.85	0.46	Negative	Negative
8/26/2019	20.8	7.45	3.39	0.79	0.76	1.20	0	78	11	12	74	7.9	246	-0.73	0.92	0.44	Negative	Negative
8/27/2019	21.0	7.49	3.40	0.78		1.18	0	79	11	14	76	8.1	252	-0.67	0.79	0.47	Negative	Negative
8/28/2019	21.0	7.50	3.41	0.74		1.18	0	82	12	14	76	8.0	251	-0.65	0.86	0.47	Negative	Negative
8/29/2019	20.9	7.48	3.41	0.77		1.19	0	83	12	15	76	7.9	251	-0.67	0.77	0.47	Negative	Negative
8/30/2019	20.6	7.43	3.41	0.78		1.22	0	77	12	12	74	8.0	235	-0.77	1.00	0.47	Negative	Negative
8/31/2019	18.3	7.34	3.40	0.76		1.25	0	79	12	11	76	9.5	223	-0.87	1.09	0.44	Negative	Negative
Avg	19.8	7.46	3.39	0.78	0.77	1.21	0	78	11	12	75	8.3	244	-0.74	0.92	0.44	NA	NA
Min	16.8	7.34	3.36	0.74	0.73	1.18	0	74	10	8	64	7.3	214	-0.91	0.76	0.34	NA	NA
Max	21.2	7.56	3.44	0.83	0.82	1.25	0	88	12	15	86	9.5	715	-0.56	1.25	0.49	NA	NA



Turbidity										
Date	Raw Water		Clarified Water	Membrane Feed Water	Combined Membrane Filtrate					Finished Water
	Avg	Max	Avg	Avg	Avg	Max	# Samples	# > 0.3	% Exceeded	Avg
	NTU									
	AIT-1000-1		AIT-5030-1	AIT-1035-3	AIT-4000-1				Calculated	
8/1/2019	0.42	0.73	1.65	0.42	0.019	0.019	96	0	0.0	0.015
8/2/2019	0.49	0.72	1.74	0.48	0.019	0.020	96	0	0.0	0.015
8/3/2019	0.58	1.02	3.04	0.53	0.020	0.020	96	0	0.0	0.015
8/4/2019	0.53	2.05	2.36	0.54	0.020	0.021	96	0	0.0	0.015
8/5/2019	0.53	0.89	2.08	0.50	0.020	0.020	96	0	0.0	0.015
8/6/2019	0.72	2.62	2.32	0.60	0.020	0.021	96	0	0.0	0.014
8/7/2019	0.46	1.16	2.02	0.58	0.020	0.021	96	0	0.0	0.014
8/8/2019	0.44	2.45	1.99	0.45	0.020	0.021	96	0	0.0	0.014
8/9/2019	0.61	0.99	1.22	0.54	0.019	0.020	96	0	0.0	0.014
8/10/2019	0.67	2.37	1.13	0.73	0.019	0.020	96	0	0.0	0.014
8/11/2019	0.87	2.02	1.04	0.76	0.019	0.020	96	0	0.0	0.014
8/12/2019	0.60	1.66	1.40	0.72	0.019	0.019	96	0	0.0	0.014
8/13/2019	0.47	1.83	1.03	0.60	0.019	0.019	96	0	0.0	0.014
8/14/2019	0.41	0.74	1.33	0.51	0.019	0.020	96	0	0.0	0.014
8/15/2019	0.66	2.31	1.07	0.55	0.019	0.020	96	0	0.0	0.015
8/16/2019	1.51	3.04	1.17	0.93	0.019	0.020	96	0	0.0	0.014
8/17/2019	0.83	1.54	2.93	1.40	0.020	0.020	96	0	0.0	0.014
8/18/2019	0.77	1.33	1.58	1.04	0.020	0.020	96	0	0.0	0.014
8/19/2019	1.12	4.26	2.05	1.10	0.019	0.020	96	0	0.0	0.014
8/20/2019	0.83	1.77	2.32	1.14	0.020	0.020	96	0	0.0	0.014
8/21/2019	0.68	2.59	1.51	0.85	0.020	0.020	96	0	0.0	0.014
8/22/2019	0.64	1.40	1.22	0.74	0.020	0.021	96	0	0.0	0.014
8/23/2019	0.78	5.41	1.32	0.72	0.020	0.022	96	0	0.0	0.014
8/24/2019	0.90	1.78	1.37	0.79	0.020	0.024	96	0	0.0	0.014
8/25/2019	1.53	2.48	3.34	1.29	0.021	0.023	96	0	0.0	0.014
8/26/2019	1.66	2.91	1.36	1.47	0.021	0.023	96	0	0.0	0.014
8/27/2019	1.73	4.42	2.01	1.69	0.021	0.024	96	0	0.0	0.014
8/28/2019	1.76	3.63	6.21	1.83	0.021	0.022	96	0	0.0	0.014
8/29/2019	1.43	3.86	2.59	1.71	0.020	0.021	96	0	0.0	0.014
8/30/2019	0.76	3.79	1.68	1.22	0.020	0.021	96	0	0.0	0.014
8/31/2019	0.77	2.13	1.05	0.93	0.019	0.019	96	0	0.0	0.014
Avg	0.84	2.25	1.91	0.88	0.020	0.021	96	0	0.0	0.014
Min	0.41	0.72	1.03	0.42	0.019	0.019	96	0	0.0	0.014
Max	1.76	5.41	6.21	1.83	0.021	0.024	96	0	0.0	0.015



Note: % Exceeded are 4 hr compliance periods where 50% of the samples are greater than 0.3 NTU

Date	Membrane Integrity																							
	Membrane 1			Membrane 2			Membrane 3			Membrane 4			Membrane 5			Membrane 6			Membrane 7			Membrane 8		
	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail
8/1/2019	15.2	14.8	PASS	14.3	13.8	PASS	14.3	13.8	PASS	14.5	14.2	PASS	14.3	13.8	PASS	14.5	14.2	PASS	14.3	14.0	PASS	14.4	13.8	PASS
8/2/2019	14.4	13.9	PASS	14.7	14.3	PASS	14.2	13.7	PASS	14.5	14.2	PASS	14.2	13.6	PASS	14.4	14.1	PASS	14.3	14.0	PASS	14.5	14.1	PASS
8/3/2019	14.7	14.2	PASS	14.3	13.8	PASS	15.4	15.2	PASS	14.5	14.2	PASS	14.2	13.6	PASS	14.5	14.1	PASS	15.0	14.6	PASS	14.4	14.0	PASS
8/4/2019	14.8	14.3	PASS	14.3	13.8	PASS	14.2	13.7	PASS	14.5	14.2	PASS	14.2	13.6	PASS	14.5	14.2	PASS	14.5	14.1	PASS	14.3	13.7	PASS
8/5/2019	14.3	13.8	PASS	14.3	13.8	PASS	14.4	14.0	PASS	14.5	14.2	PASS	14.0	13.4	PASS	14.5	14.2	PASS	14.5	14.2	PASS	14.3	13.7	PASS
8/6/2019	14.3	13.8	PASS	14.3	13.8	PASS	14.3	13.8	PASS	14.6	14.2	PASS	14.0	13.4	PASS	14.5	14.2	PASS	14.3	13.9	PASS	14.1	13.6	PASS
8/7/2019	14.4	13.9	PASS	14.3	13.8	PASS	14.2	13.7	PASS	14.5	14.2	PASS	14.0	13.4	PASS	14.5	14.1	PASS	14.3	14.0	PASS	14.4	14.0	PASS
8/8/2019	14.4	13.9	PASS	14.6	14.2	PASS	14.3	13.8	PASS	14.5	14.2	PASS	14.1	13.5	PASS	14.5	14.1	PASS	14.3	13.9	PASS	14.4	13.9	PASS
8/9/2019	15.2	14.9	PASS	14.3	13.8	PASS	15.5	15.4	PASS	14.5	14.2	PASS	14.0	13.4	PASS	14.4	14.1	PASS	14.5	14.1	PASS	14.2	13.6	PASS
8/10/2019	14.7	14.3	PASS	14.3	13.8	PASS	14.4	13.9	PASS	14.5	14.2	PASS	14.2	13.7	PASS	14.4	14.1	PASS	14.6	14.3	PASS	14.3	13.8	PASS
8/11/2019	15.3	14.9	PASS	14.3	13.8	PASS	15.1	14.8	PASS	14.5	14.2	PASS	14.3	13.8	PASS	14.4	14.1	PASS	14.5	14.2	PASS	14.3	13.7	PASS
8/12/2019	14.5	14.0	PASS	14.3	13.8	PASS	14.3	13.8	PASS	14.5	14.2	PASS	15.0	14.6	PASS	14.4	14.1	PASS	14.5	14.2	PASS	14.3	13.7	PASS
8/13/2019	14.7	14.3	PASS	14.3	13.8	PASS	14.3	13.8	PASS	14.5	14.2	PASS	14.3	13.7	PASS	14.5	14.1	PASS	14.5	14.1	PASS	14.3	13.9	PASS
8/14/2019	14.5	14.0	PASS	14.3	13.8	PASS	14.8	14.4	PASS	14.4	14.0	PASS	14.1	13.5	PASS	14.4	14.1	PASS	14.7	14.4	PASS	14.3	13.7	PASS
8/15/2019	14.6	14.1	PASS	14.3	13.8	PASS	15.4	15.1	PASS	14.5	14.2	PASS	14.5	14.0	PASS	14.4	14.1	PASS	14.4	14.0	PASS	14.3	13.7	PASS
8/16/2019	14.5	14.0	PASS	14.3	13.8	PASS	15.4	15.2	PASS	14.5	14.2	PASS	14.5	14.0	PASS	14.5	14.1	PASS	14.6	14.2	PASS	14.2	13.6	PASS
8/17/2019	14.2	13.8	PASS	14.3	13.7	PASS	14.7	14.2	PASS	14.6	14.3	PASS	14.0	13.6	PASS	14.5	14.1	PASS	15.0	14.6	PASS	14.3	13.7	PASS
8/18/2019	14.3	13.8	PASS	14.2	13.7	PASS	14.6	14.1	PASS	14.5	14.2	PASS	14.0	13.5	PASS	14.5	14.1	PASS	14.9	14.6	PASS	14.1	13.6	PASS
8/19/2019	14.4	13.9	PASS	14.3	13.8	PASS	14.2	13.8	PASS	14.5	14.2	PASS	14.2	13.6	PASS	14.4	14.0	PASS	14.6	14.2	PASS	14.1	13.6	PASS
8/20/2019	15.0	14.6	PASS	14.3	13.8	PASS	15.1	14.8	PASS	14.5	14.2	PASS	14.2	13.6	PASS	14.5	14.2	PASS	14.2	13.9	PASS	14.3	13.7	PASS
8/21/2019	14.6	14.1	PASS	14.3	13.9	PASS	14.3	13.8	PASS	14.5	14.2	PASS	15.0	14.6	PASS	14.5	14.2	PASS	14.3	13.9	PASS	14.2	13.7	PASS
8/22/2019	14.3	13.8	PASS	14.3	13.7	PASS	14.4	13.9	PASS	14.5	14.2	PASS	14.2	13.6	PASS	14.4	14.0	PASS	15.0	14.6	PASS	14.3	13.8	PASS
8/23/2019	14.3	13.8	PASS	14.2	13.7	PASS	14.6	14.1	PASS	14.4	14.0	PASS	14.3	13.7	PASS	14.4	14.1	PASS	14.3	13.9	PASS	14.4	14.0	PASS
8/24/2019	14.3	13.8	PASS	14.4	14.0	PASS	14.5	14.0	PASS	Out of service 8/23/19			14.0	13.5	PASS	14.5	14.2	PASS	14.4	14.0	PASS	14.2	13.6	PASS
8/25/2019	14.3	13.7	PASS	14.3	13.8	PASS	14.2	13.7	PASS	In service 8/26/19			14.0	13.4	PASS	14.4	14.1	PASS	14.4	14.0	PASS	14.2	13.7	PASS
8/26/2019	14.2	13.7	PASS	14.5	14.0	PASS	14.1	13.6	PASS	14.5	14.2	PASS	14.0	13.5	PASS	14.5	14.1	PASS	14.3	13.9	PASS	14.2	13.6	PASS
8/27/2019	14.2	13.7	PASS	14.4	13.9	PASS	14.5	14.1	PASS	14.5	14.1	PASS	14.4	13.9	PASS	14.4	14.1	PASS	14.2	13.8	PASS	14.2	13.6	PASS
8/28/2019	14.4	13.9	PASS	14.2	13.7	PASS	14.2	13.6	PASS	14.6	14.3	PASS	14.0	13.4	PASS	14.5	14.2	PASS	14.2	13.8	PASS	14.2	13.7	PASS
8/29/2019	14.5	14.1	PASS	14.2	13.7	PASS	14.4	13.9	PASS	14.5	14.1	PASS	14.0	13.5	PASS	14.4	14.1	PASS	14.3	13.9	PASS	14.1	13.4	PASS
8/30/2019	14.6	14.2	PASS	14.3	13.7	PASS	14.3	13.8	PASS	14.5	14.2	PASS	14.9	14.4	PASS	14.4	14.0	PASS	15.2	14.9	PASS	14.4	13.8	PASS
8/31/2019	14.6	14.1	PASS	14.3	13.7	PASS	14.3	13.8	PASS	14.6	14.2	PASS	14.4	13.8	PASS	14.5	14.1	PASS	14.3	13.9	PASS	14.5	14.1	PASS

Integrity test performed every 24-hours



Treatment Chemical Dosages											
Date	Treated Water	Sodium Hypochlorite					Phosphoric Acid		Hydroflourosilicic Acid		
		Raw Water	Membrane Feed Water	Dose pre-FW Tanks	Treated Water	Post FW Tanks	Dose pre-FW Tanks	Post FW Tanks	Raw Water	Dose pre-FW Tanks	Post FW Tanks
	Volume	Free Cl ₂					PO4		F		
	MG	mg/L					mg/L		mg/L		
	FIT-4000-1	AIT-1035-2	AIT-1035-4	Added	AIT-4030-1	AIT-4050-1	Added	AIT-4040-5	Lab	Added	Lab
8/1/2019	11.1	0.30	0.25	1.19	1.34	1.22	3.44	3.43	0.09	0.74	0.80
8/2/2019	11.2	0.27	0.20	1.24	1.35	1.21	3.44	3.43	0.09	0.74	0.81
8/3/2019	10.4	0.24	0.15	1.34	1.37	1.20	3.44	3.44	0.09	0.74	0.82
8/4/2019	10.7	0.29	0.14	1.33	1.40	1.21	3.44	3.43	0.09	0.74	0.81
8/5/2019	11.7	0.30	0.18	1.22	1.39	1.23	3.44	3.42	0.09	0.70	0.79
8/6/2019	9.7	0.25	0.14	1.31	1.38	1.20	3.44	3.40	0.09	0.64	0.78
8/7/2019	10.8	0.34	0.15	1.26	1.41	1.23	3.44	3.40	0.08	0.64	0.77
8/8/2019	9.4	0.42	0.24	1.12	1.39	1.25	3.44	3.40	0.09	0.64	0.78
8/9/2019	9.9	0.37	0.26	1.14	1.36	1.21	3.44	3.39	0.08	0.64	0.76
8/10/2019	10.1	0.48	0.27	1.08	1.37	1.23	3.44	3.38	0.06	0.64	0.74
8/11/2019	10.5	0.53	0.34	1.02	1.36	1.23	3.44	3.37	0.08	0.64	0.80
8/12/2019	11.1	0.43	0.35	1.00	1.35	1.22	3.44	3.36	0.08	0.64	0.76
8/13/2019	11.5	0.43	0.31	0.98	1.38	1.24	3.44	3.37	0.08	0.64	0.78
8/14/2019	10.6	0.40	0.31	0.96	1.37	1.24	3.44	3.38	0.08	0.63	0.78
8/15/2019	9.5	0.35	0.28	1.00	1.37	1.21	3.44	3.37	0.09	0.62	0.77
8/16/2019	9.1	0.14	0.17	1.14	1.36	1.19	3.44	3.37	0.09	0.62	0.78
8/17/2019	9.2	0.34	0.12	1.15	1.40	1.19	3.44	3.37	0.09	0.62	0.80
8/18/2019	9.6	0.28	0.16	1.15	1.39	1.21	3.44	3.37	0.08	0.60	0.81
8/19/2019	10.8	0.14	0.11	1.20	1.39	1.22	3.45	3.38	0.09	0.60	0.81
8/20/2019	10.4	0.20	0.09	1.15	1.41	1.21	3.46	3.39	0.09	0.59	0.83
8/21/2019	9.2	0.24	0.14	1.11	1.39	1.22	3.46	3.39	0.09	0.61	0.76
8/22/2019	10.0	0.21	0.13	1.16	1.40	1.23	3.46	3.38	0.09	0.61	0.74
8/23/2019	9.5	0.54	0.16	1.10	1.37	1.23	3.46	3.39	0.09	0.65	0.77
8/24/2019	10.2	0.22	0.18	1.11	1.36	1.21	3.46	3.39	0.09	0.65	0.77
8/25/2019	10.0	0.09	0.09	1.23	1.38	1.18	3.46	3.39	0.09	0.65	0.79
8/26/2019	9.5	0.07	0.05	1.30	1.42	1.20	3.46	3.39	0.09	0.64	0.79
8/27/2019	9.1	0.05	0.03	1.34	1.44	1.18	3.46	3.40	0.09	0.61	0.78
8/28/2019	9.7	0.05	0.03	1.40	1.44	1.18	3.46	3.41	0.10	0.60	0.74
8/29/2019	9.2	0.10	0.03	1.37	1.44	1.19	3.46	3.41	0.09	0.60	0.77
8/30/2019	9.0	0.62	0.13	1.24	1.45	1.22	3.46	3.41	0.08	0.60	0.78
8/31/2019	8.4	0.99	0.43	0.94	1.38	1.25	3.46	3.40	0.08	0.60	0.76
Avg	10.0	0.31	0.18	1.17	1.39	1.21	3.45	3.39	0.09	0.64	0.78
Min	8.4	0.05	0.03	0.94	1.34	1.18	3.44	3.36	0.06	0.59	0.74
Max	11.7	0.99	0.43	1.40	1.45	1.25	3.46	3.44	0.10	0.74	0.83



Disinfection CT														
Date	Pipeline CT				FW Tank CT						Compliance			
	Whitestone	Travel Time	Residual	CT	FW Tank 1	FW Tank 2	Plant	Contact Time	Free Cl ₂	CT	Total CT	Temp	CT	CT
	Flow	Min	RW	Achieved	Min Level	Min Level	Flow	Min	Min	Achieved	Achieved	Avg	Required	Met
	MGD	Minutes	mg/L	mg-min/L	ft	ft	MGD	Minutes	mg/L	mg-min/L	mg-min/L	°C	mg-min/L	Y/N
Entry	Calculated	AIT-1035-2	Calculated	LIT-4005-1	LIT-4005-2	Calculated	Calculated	Calculated	Calculated	Calculated	TIT-1000	Calculated	Calculated	
8/1/2019	63.0	1,987	0.30	599	29.0	23.7	11.0	328	1.19	389.55	989.01	19.7	4.00	Y
8/2/2019	72.1	1,736	0.27	475	29.0	23.1	10.9	326	1.19	387.64	862.36	20.0	4.00	Y
8/3/2019	80.3	1,558	0.24	379	29.0	24.3	10.3	355	1.18	417.48	796.30	20.3	2.00	Y
8/4/2019	80.5	1,553	0.29	446	29.0	24.0	10.5	345	1.20	412.91	858.89	20.6	2.00	Y
8/5/2019	80.8	1,549	0.30	458	29.1	23.5	11.6	312	1.21	377.59	835.12	20.7	2.00	Y
8/6/2019	75.9	1,649	0.25	404	29.0	25.3	9.5	392	1.16	455.50	859.52	21.0	2.00	Y
8/7/2019	67.8	1,844	0.34	635	29.2	22.1	10.6	331	1.20	395.92	1,030.81	20.7	2.00	Y
8/8/2019	62.2	2,012	0.42	842	28.9	24.1	9.3	391	1.21	472.70	1,315.02	20.3	2.00	Y
8/9/2019	59.6	2,098	0.37	786	29.0	24.2	9.8	373	1.11	412.74	1,199.12	19.8	4.00	Y
8/10/2019	76.4	1,637	0.48	794	28.9	23.8	9.8	369	1.20	443.71	1,237.38	19.0	4.00	Y
8/11/2019	76.7	1,630	0.53	862	29.1	24.0	10.3	355	1.21	429.36	1,291.44	18.6	4.00	Y
8/12/2019	71.4	1,752	0.43	753	29.1	24.4	10.9	337	1.20	402.84	1,155.50	18.8	4.00	Y
8/13/2019	59.8	2,092	0.43	891	29.1	23.4	11.3	320	1.20	382.65	1,273.70	19.0	4.00	Y
8/14/2019	56.3	2,222	0.40	898	29.0	22.0	10.7	328	1.20	392.14	1,290.41	19.4	4.00	Y
8/15/2019	55.8	2,241	0.35	779	28.9	22.9	9.2	387	1.19	460.71	1,239.64	19.8	4.00	Y
8/16/2019	59.0	2,121	0.14	296	28.9	25.1	9.0	410	1.15	470.68	766.72	20.1	2.00	Y
8/17/2019	76.3	1,639	0.34	560	28.9	24.3	9.0	406	1.16	471.32	1,031.77	20.4	2.00	Y
8/18/2019	76.6	1,633	0.28	452	28.9	24.2	9.5	384	1.18	454.38	906.12	20.6	2.00	Y
8/19/2019	69.5	1,799	0.14	260	29.1	24.9	10.6	348	1.19	414.15	674.64	20.7	2.00	Y
8/20/2019	66.8	1,873	0.20	369	28.9	24.8	10.3	359	1.20	429.09	798.58	20.7	2.00	Y
8/21/2019	64.0	1,955	0.24	461	28.8	24.5	9.0	404	1.20	483.04	943.94	20.7	2.00	Y
8/22/2019	58.2	2,149	0.21	457	28.9	23.7	9.8	369	1.20	440.89	897.50	20.5	2.00	Y
8/23/2019	56.7	2,206	0.54	1188	28.9	24.6	9.4	390	1.19	463.72	1,652.05	20.3	2.00	Y
8/24/2019	69.0	1,812	0.22	393	28.9	24.9	10.0	368	1.18	434.84	828.11	20.4	2.00	Y
8/25/2019	69.3	1,804	0.09	170	28.8	24.2	9.7	374	1.15	428.95	598.93	20.7	2.00	Y
8/26/2019	69.2	1,809	0.07	135	28.8	23.8	9.5	380	1.16	441.87	576.53	20.8	2.00	Y
8/27/2019	65.4	1,914	0.05	88	28.9	24.0	8.9	407	1.15	467.61	555.80	20.9	2.00	Y
8/28/2019	54.6	2,291	0.05	104	28.9	24.3	9.5	385	1.14	438.87	542.91	20.8	2.00	Y
8/29/2019	53.7	2,331	0.10	232	28.8	25.0	9.0	408	1.14	465.30	696.97	20.8	2.00	Y
8/30/2019	56.9	2,198	0.62	1359	28.9	23.4	8.9	404	1.17	472.46	1,831.05	20.1	2.00	Y
8/31/2019	67.9	1,843	0.99	1,822	28.9	24.7	8.3	445	1.21	538.82	2,361.00	18.4	4.00	Y
Avg	66.8	1,901	0.31	592	29.0	24.0	9.9	371	1.18	437.08	1,028.93	20.1	2.65	NA
Min	53.7	1,549	0.05	88	28.8	22.0	8.3	312	1.11	377.59	542.91	18.4	2.00	NA
Max	80.8	2,331	0.99	1,822	29.2	25.3	11.6	445	1.21	538.82	2,361.00	21.0	4.00	NA



Notes:

Pipeline volume factor in SMMWSC to RW tank: 125,090 MG-min/day

Distribution System Monitoring

Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl₂)

WSSN:	0072	0390				0400			0470							0485					0517	0518		2180		
	Akron	Bangor Twp.				Bangor Monitor Dist.			Bay City							Bay County					Beaver Rd	Beaver Twp		Essexville		
	Date	1	3	4	5	6	7	9	10	11	12	13	14	15	16	17	18	19	20	22	24	26	29	30	32	
8/1/2019		0.78	0.54				0.97	1.10		0.72	0.26		0.77	0.11	0.97	0.53										
8/2/2019																										
8/3/2019																										
8/4/2019																										
8/5/2019																										
8/6/2019																										
8/7/2019										0.58	0.12	0.33	0.74	0.15	0.90	0.69	0.71	0.74	0.80	0.81	0.48				0.84	
8/8/2019		0.68	0.35	0.21	1.13			1.10														0.20				
8/9/2019																										
8/10/2019																										
8/11/2019																										
8/12/2019										0.80	0.24	0.37	0.44	0.11	0.89	0.61									1.02	
8/13/2019																	0.90	1.01	0.88	0.90	0.93	0.99				
8/14/2019																										
8/15/2019			0.39		1.13					0.76	0.22	0.42	0.57	0.18	0.89	0.47										
8/16/2019																										
8/17/2019																										
8/18/2019																										
8/19/2019																									0.81	
8/20/2019	0.36	0.42		0.79																						
8/21/2019										0.62	0.12	0.39	0.75	0.10	0.85	0.38										
8/22/2019																							0.40			
8/23/2019																										
8/24/2019																										
8/25/2019																										
8/26/2019										0.50	0.10	0.30	0.50	0.11	0.78	0.31									0.80	
8/27/2019																										
8/28/2019																										
8/29/2019										0.62	0.13	0.23	0.54	0.10	0.84	0.34										
8/30/2019																										
8/31/2019																										
Average	0.36		0.64				1.06					0.47						0.82			0.99		0.30		0.87	
Min	0.36		0.21				0.97					0.10						0.48			0.99		0.20		0.80	
Max	0.36		1.13				1.10					0.97						1.01			0.99		0.40		1.02	



MONITORING STATION ADDRESSES

- | | | |
|----------------------------------------------|---------------------------------------------------|-------------------------------------------------|
| 1. Sample station at corner of 5758 M-25 & F | 11. Number 1 Fire Station, 1401 Center Ave | 19. Dore's M-84 Party Store, 6183 WS Saginaw Rd |
| 3. Bangor Fire Station, 3921 Wheeler | 12. Number 2 Fire Station, 1000 Fremont Ave | 20. Pump Station #13, 6000 WS Saginaw Rd |
| 4. BCDWS Admin. Bldg. 3933 Patterson Rd. | 13. Skizak's Sport Shop, 807 Salzburg Ave | 22. Duce's Char House, 432 N. Tuscola Rd |
| 5. 7-11, 3543 S. Old Kawkawlin Rd. | 14. Number 4 Fire Station, 212 S. Dean St | 24. Little Learners Daycare, 1694 Cass Ave. |
| 6. Admiral Petroleum, 314 S Euclid Ave. | 15. Number 5 Fire Station, 1209 Smith St | 26. Wieland Contracting, 2443 S Mackinaw Rd |
| 7. Sequin Lumber, 3881 Euclid Ave | 16. Bay City Hall, 301 Washington Ave | 29. Sample Station, 2515 S. 11 Mile Rd |
| 9. B's Boutique, 2981 Midland Rd | 17. Skipper Buds Marina, 1809 S Water St | 30. Sample Station, 340 W. Beaver Rd |
| 10. Little Caesars, 3475 E North Union Rd | 18. Bay Valley Animal Hospital 6015 WS Saginaw Rd | 32. Essexville City Hall, 1107 Woodside Ave |

Distribution System Monitoring																								
Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl2)																								
WSSN:	2465		2960			3565			3570		4280		4440			5330		5335		5540	7125			7134
Date	Fraser Twp.		Hampton Twp.			Kawkawlin Twp.			Kawkawlin Met.		Merritt Twp.		Monitor Twp.			City Pinconning		Pinconning Twp.		Portsmouth	Williams Twp.			Wisner
	34	35	37	38	39	40	41	42	43	45	46	48	49	52	55	58	59	61	63	65	68	69	70	72
8/1/2019	0.83	0.93				1.08	0.79		0.72					1.05	0.82	0.75	0.41		0.77	0.61				
8/2/2019																								
8/3/2019																								
8/4/2019																								
8/5/2019			0.69	0.66	0.57																			
8/6/2019										0.46										0.65				0.31
8/7/2019																								
8/8/2019													1.02	0.78	0.68						0.56	0.66	0.67	
8/9/2019																								
8/10/2019																								
8/11/2019																								
8/12/2019			0.73	0.83	0.56																			
8/13/2019								0.85	0.75		0.54						0.35							
8/14/2019																								
8/15/2019																					0.56	0.81	0.72	
8/16/2019																								
8/17/2019																								
8/18/2019																								
8/19/2019																								
8/20/2019			0.32	0.86	0.52																			
8/21/2019																								
8/22/2019																								
8/23/2019																								
8/24/2019																								
8/25/2019																								
8/26/2019			0.54																					
8/27/2019																								
8/28/2019																								
8/29/2019																								
8/30/2019																								
8/31/2019																								
Average	0.88		0.63			0.91			0.74		0.50		0.85			0.38		0.69		0.65	0.66			0.31
Min	0.83		0.32			0.79			0.72		0.46		0.68			0.35		0.61		0.65	0.56			0.31
Max	0.93		0.86			1.08			0.75		0.54		1.05			0.41		0.77		0.65	0.81			0.31



MONITORING STATION ADDRESSES

- 34. Fraser Elevated Tank, 2949 1/2 N. Huron Rd
- 35. Lloyd's Cabinet, 1947 N Huron Rd
- 37. Hampton DPW, 950 Wagner Rd.
- 38. Bay County Golf Course, 584 W Hampton Rd.
- 39. Sewer Lift Station, 902 Nebobish Rd.
- 40. Bay Co. Road Commisison, 2600 E Beaver Rd
- 41. Parish Rd. Elevated Tank, 1770 E. Parish Rd
- 42. Linwood Tile, 205 S Huron Rd

- 43. Kawkawlin Party Store, 105 Grove St
- 45. Kawkawlin Restaurant, 103 S Huron Rd
- 46. John's Bar, 1476 S Tuscola Rd
- 48. Tool Shed Bar, 12 W Munger Rd
- 49. Wilder Rd Party Store, 2951 E Wilder Rd
- 52. Monitor Twp. Elevated Tank, 1611 E. Midland Rd
- 55. Auburn Fertilizer, 4640 S 7 Mile Rd
- 58. Pinconning City Hall, 208 S Manitou St

- 59. Marathon Gas Station, 511 S Mabel St
- 61. Pinconning Meter Pit, 3005 N Huron Rd
- 63. Master Meter Pit, 2865 Pinconning Rd
- 65. Ike's Welding, 50 N Finn Rd
- 68. Williams Township Hall, 1080 W Midland Rd
- 69. Pump Station, 490 W. Salzburg & 9 Mile Rd
- 70. 11 Mile Elevated Tank, 5003 S. 11 Mile Rd
- 72. Lindy's Sales, 9051 M-25

Distribution System Bacteriological

Water Supplier Bacteriological Analysis Report

Name of Water Supply

Bay Area Water Treatment Plant

MICHIGAN DEPARTMENT OF PUBLIC HEALTH

Bureau of Environmental Health

Water Supplier Bacteriological Analysis Report

August, 2019

COUNTY	COMMUNITY	WSSN NUMBER	DISTRIBUTION SYSTEM SAMPLES				
			avg free cl2 mg/L	NUMBER REQUIRED	NUMBER COLLECTED	NUMBER POSITIVE	NUMBER REPEAT SAMPLES
Tuscola	Akron	0072	0.36	1	1	0	0
BAY	Bangor Township	0390	0.64	10	10	0	0
BAY	Bangor-Monitor Dist.	0400	1.06	3	3	0	0
BAY	Bay City	0470	0.47	40	48	0	0
BAY	Bay County (Frankl./Monitor/Portsm.)	0485	0.82	10	10	0	0
BAY	Beaver Road Area	0517	0.99	1	1	0	0
BAY	Beaver Township	0518	0.30	2	2	0	0
BAY	Essexville	2180	0.87	4	4	0	0
BAY	Fraser Township	2465	0.88	2	2	0	0
BAY	Hampton Township	2960	0.63	10	10	0	0
BAY	Kawkawlin Township	3565	0.91	3	3	0	0
BAY	Kawkawlin Metro Dist.	3570	0.74	2	2	0	0
BAY	Merritt Township	4280	0.50	2	2	0	0
BAY	Monitor Township	4440	0.85	6	6	0	0
BAY	City of Pinconning	5330	0.38	2	2	0	0
BAY	Pinconning Township	5335	0.69	2	2	0	0
BAY	Portsmouth Township	5540	0.65	1	1	0	0
BAY	Williams Township	7125	0.66	6	6	0	0
Tuscola	Wisner	7134	0.31	1	1	0	0
Average Free Cl2 Residual of All Distribution Sites			0.67	mg/L			
1. Total distribution samples			116				
2. Total distribution samples with detectable free cl2 residual			116				
3. Total distribution samples with no detectable free cl2 residual			0				
4. Total distribution samples with no detectable free cl2 residual and HPC was <500			NA				
5. Total distribution samples with no detectable free cl2 residual and HPC was >500			NA				
6. Percent of distribution samples with no detectable free cl2 residual			0.00%				
7. Percent shown line #6 in previous monthly report			0.00%				

